

Facility Summary in CARBON County in the City of BELFRY

Location: BLACKS SERVICE STATION
332 BROADWAY AVE
BELFRY, MT 59008 CARBON

Sys Fac ID: 05-02954

Last Inspected On: 5/8/2013

Operating Permit Renewal Date: 6/8/2016

Contact: Earl Black, (406) 664-3289

Owners/Operators: Earl Black, Owner (406)-664-3289 PO BOX 50
BELFRY MT 59008-0058
Louise Black, UST Class A Operator
Louise Black, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
9	22	5/1/1993	Bare Steel	Fiberglass Reinforced Plastic	
449	Yes		None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	MLLD Line Tightness Testing	
1,000		5/8/2013			
10	22	5/1/1993	Bare Steel	Fiberglass Reinforced Plastic	
450	Yes		None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Deferred	MLLD Line Tightness Testing	
1,000		5/8/2013			

Facility Summary in CARBON County in the City of BRIDGER

Location: MAVERIK INC #7
US HIGHWAY 310 N
BRIDGER, MT 59014 CARBON

Sys Fac ID: 05-00218

Last Inspected On: 7/20/2015

Operating Permit Renewal Date: 9/15/2018

Contact: Dennis Riding, (801) 936-5557

Owners/Operators: Maverik Inc, Owner Maverik Inc #7, Operator Dennis Riding, UST Class A Operator Breann Christiansen, UST Class B Operator Dennis Riding, UST Class B Operator	(801)-936-5557 (406)-662-3356	880 W CENTER ST NORTH SALT LAKE UT 84054-2913 HWY 310 NORTH BRIDGER MT 59014
--	--------------------------------------	---

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	24	7/21/1991	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
530			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
5	24	7/21/1991	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
531			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CARBON County in the City of BRIDGER

Location: TOWN & COUNTRY SUPPLY BRIDGER
209 MAIN ST
BRIDGER, MT 59014 CARBON

Contact: (406) 662-3623

Sys Fac ID: 05-04498
Last Inspected On: 5/15/2015
Operating Permit Renewal Date: 10/27/2018

Owners/Operators: Town & Country Supply Association, Owner (406)-628-6314 PO BOX 367
LAUREL MT 59044-0367

Wesley Burley, UST Class A Operator
Steven Shelton, UST Class A Operator
Mike Ventling, UST Class A Operator
Leilani McCarthy, UST Class B Global Operator
Steven Shelton, UST Class B Global Operator
Mike Ventling, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
6	25	5/18/1990	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1515			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		6/14/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000		1/8/2012	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
7	25	5/18/1990	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1516			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		6/14/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000		1/2/2012	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
8	25	5/18/1990	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1517			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		6/14/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000		1/2/2012	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in CARBON County in the City of BRIDGER

Location: TOWN & COUNTRY SUPPLY BRIDGER
 209 MAIN ST
 BRIDGER, MT 59014 CARBON
Contact: (406) 662-3623

Sys Fac ID: 05-04498
Last Inspected On: 5/15/2015
Operating Permit Renewal Date: 10/27/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
9	12	7/1/2003	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4849			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		5/15/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
2,000		12/31/2011	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in CARBON County in the City of JOLIET

Location: TOWN OF JOLIET
116 S MAIN ST
JOLIET, MT 59041 CARBON

Sys Fac ID: 05-00189

Last Inspected On: 3/17/2014

Operating Permit Renewal Date: 5/16/2017

Contact: Gayle Langlois, (406) 962-3567

Owners/Operators: Town of Joliet, Owner

(406)-962-3567

PO BOX 210

JOLIET MT 59041-0210

Dale Limberhand, UST Class A Operator

Dale Limberhand, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	18	9/1/1997	Steel Clad	Steel	Flapper Valve (Auto Shutoff)
2127			Double-Walled	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		3/17/2014	Manual Interstitial Monitor	Deferred	
560					

Facility Summary in CARBON County in the City of JOLIET

Location: CARBON COUNTY DIST 2 SHOP
201 STATE ST
JOLIET, MT 59041 CARBON

Sys Fac ID: 05-01853

Last Inspected On: 2/10/2016

Operating Permit Renewal Date: 9/14/2016

Contact: Alvin Swigert, (406) 962-3546

Owners/Operators: Carbon County Road Dist, Owner

(406)-446-1595

ATTN DAVID DAVIDSON

PO BOX 887

RED LODGE MT 59068-0887

Shawn Maines, UST Class A Operator

Jerrid E Bergum, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	24	1/30/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
518			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		4/22/2013	Automatic Tank Gauging 0.2	Not Listed	
1,000					
2	24	1/30/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
519			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		4/22/2013	Automatic Tank Gauging 0.2	Not Listed	
1,000					

Facility Summary in CARBON County in the City of JOLIET

Location: JOLIET SCHOOL DIST 7
131 N MAIN ST
JOLIET, MT 59041 CARBON

Sys Fac ID: 05-05353

Last Inspected On: 4/24/2014

Operating Permit Renewal Date: 6/25/2017

Contact: Russ Salo, (406) 962-3541

Owners/Operators: School Dist 7 Joliet, Owner

(406)-962-3541

PO BOX 590
JOLIET MT 59041-0590

Dale Limberhand, UST Class A Operator

Flint Salo, UST Class A Operator

Dale Limberhand, UST Class B Operator

Flint Salo, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	16	7/1/1999	Steel Clad	Steel	Flapper Valve (Auto Shutoff)
4091			Double-Walled	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		4/6/2011	Manual Interstitial Monitor	Deferred	
1,000					

Facility Summary in CARBON County in the City of JOLIET

Location: COUNTRY CORNER JOLIET
110 E FRONT ST
JOLIET, MT 59041 CARBON

Contact: Dennis Whitmore, (406) 962-3435

Sys Fac ID: 05-05577
Last Inspected On: 2/14/2014
Operating Permit Renewal Date: 4/22/2017

Owners/Operators: Dennis Whitmore, Owner (406)-651-5101 PO BOX 80391
BILLINGS MT 59108-7901

Laura Geffre, UST Class A Operator
Bill Grunstead, UST Class A Operator
Ken Jackson, UST Class A Operator
Charlie McHenry, UST Class A Operator
Roger Schmechel, UST Class A Operator
Stephanie Zierke, UST Class A Operator
Roberta Brooks, UST Class B Operator
Laura Geffre, UST Class B Operator
Kristi Johnson, UST Class B Operator
Roger Schmechel, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	29	2/22/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3925			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		2/19/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		2/14/2014	Gilbarco EMC Basic , Gilbarco		
4	28	2/22/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3926			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		2/19/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
1,500		2/14/2014	Gilbarco EMC Basic , Gilbarco		

Facility Summary in CARBON County in the City of JOLIET

Location: COUNTRY CORNER JOLIET
110 E FRONT ST
JOLIET, MT 59041 CARBON

Contact: Dennis Whitmore, (406) 962-3435

Sys Fac ID: 05-05577
Last Inspected On: 2/14/2014
Operating Permit Renewal Date: 4/22/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	28	2/22/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3927			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		2/19/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
2,500		2/14/2014	Gilbarco EMC Basic , Gilbarco		
6	17	2/1/1999	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3928			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		2/19/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		2/14/2014	Gilbarco EMC Basic , Gilbarco		

Facility Summary in CARBON County in the City of RED LODGE

Location: RAY JUDD FORD INC
120 N BROADWAY AVE
RED LODGE, MT 59068 CARBON

Contact: David Judd, (406) 855-9164

Sys Fac ID: 05-05655
Last Inspected On: 12/4/2014
Operating Permit Renewal Date: 2/19/2018

Owners/Operators: Raymond Judd Ford Inc, Owner (406)-446-1332 PO BOX 1190
RED LODGE MT 59068

David Judd, UST Class A Operator
Lauri Judd, UST Class B Operator
Evelyn Roy, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	32	4/19/1983	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
1834			Lined Interior/Impressed Current	None	Yes
Currently in Use		1/1/2008	Not Required	Safe Suction	Impressed Current
Diesel		12/4/2014	Tank Tightness Testing, Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		2/27/2002			
3	32	4/19/1983	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
1835			Lined Interior/Impressed Current	None	Yes
Currently in Use		1/1/2008	Not Required	Safe Suction	Impressed Current
Diesel		12/4/2014	Tank Tightness Testing, Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000					
4	32	4/19/1983	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
1833			Lined Interior/Impressed Current	None	Yes
Currently in Use		1/1/2008	Not Required	Safe Suction	Impressed Current
Gasoline		12/4/2014	Tank Tightness Testing, Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000					

Facility Summary in CARBON County in the City of RED LODGE

Location: ROCK CREEK CONVENIENCE STORE
1022 S ADAMS AVE
RED LODGE, MT 59068 CARBON

Sys Fac ID: 05-09748

Last Inspected On: 1/14/2015

Operating Permit Renewal Date: 3/5/2018

Contact: Lindsey Novasio, (406) 446-3123

Owners/Operators: Rockin J Inc, Owner

(406)-328-6248

JULIE & JOEL LINDGREN

PO BOX 216

RED LODGE MT 59068-0216

Joel Lindgren, UST Class A Operator

Julie Lindgren, UST Class B Operator

Julie Lindgren, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	19	7/1/1996	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
3389			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		1/14/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
8,000		4/10/2015	Gilbarco EMC Basic , Gilbarco		
5	19	7/1/1996	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
3390			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		1/14/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
4,000		4/10/2015	Gilbarco EMC Basic , Gilbarco		

Facility Summary in CARBON County in the City of RED LODGE

Location: 6 ASSISTED LLC
600 21ST ST W
RED LODGE, MT 59068 CARBON

Sys Fac ID: 05-09926

Last Inspected On: 10/31/2013

Operating Permit Renewal Date:

Contact: Marie Doman, (646) 380-8748

Owners/Operators: 6 Assisted LLC, Owner (646)-380-8748 1601 BROADWAY 12 FL
NEW YORK NY 10019
Bob Miner, UST Class A Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	17	10/8/1998	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3103			Double-Walled	Double-Walled	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Diesel		8/4/2010	Not Listed	Not Listed	
1,000					

Facility Summary in CARBON County in the City of RED LODGE

Location: Cenex Zip Trip 74
902 N BROADWAY
RED LODGE, MT 59068 CARBON

Contact: Rick Bates, (509) 535-7701

Sys Fac ID: 56-13935
Last Inspected On: 8/4/2015
Operating Permit Renewal Date: 8/6/2018

Owners/Operators: CHS Inc - Spokane Valley, Owner/Operator (509)-535-7701 16124 E MARIETTA LANE
SPOKANE VALLEY WA 99216

Sean Hurley, UST Class A Operator
Julie Lindgren, UST Class A Operator
ROBERT HAYS, UST Class B Operator
Julie Lindgren, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	00	4/10/2015	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff, High Level Alarm
5566		3/12/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000		4/13/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes
6	00	4/10/2015	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff, High Level Alarm
5567		3/12/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		4/13/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes
7	00	4/10/2015	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff, High Level Alarm
5568		3/12/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
7,000		4/13/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes

Facility Summary in CARBON County in the City of RED LODGE

Location: Cenex Zip Trip 74
902 N BROADWAY
RED LODGE, MT 59068 CARBON

Sys Fac ID: 56-13935

Last Inspected On: 8/4/2015

Operating Permit Renewal Date: 8/6/2018

Contact: Rick Bates, (509) 535-7701

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
8	00	4/10/2015	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff, High Level Alarm
5569		3/12/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000		4/13/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes

Facility Summary in CARBON County in the City of RED LODGE

Location: TOWN PUMP OF RED LODGE
615 NORTH BROADWAY
RED LODGE, MT 59068 CARBON

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 60-15212
Last Inspected On: 4/23/2013
Operating Permit Renewal Date: 7/29/2016

Owners/Operators: Town Pump Inc, Owner (406)-497-6947 PO BOX 6000
BUTTE MT 59702-2534

Trent Biggers, Operator (406)-497-6700 PO BOX 6000
BUTTE MT 59702-6000

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	03	1/16/2013	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	
5377			Double-Walled	Double-Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconciliation	Continuous Interstitial Monitor	
20,000				Stat. Inventory Reconciliation	Yes
2	03	1/16/2013	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	
5378			Double-Walled	Double-Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconciliation	Continuous Interstitial Monitor	
14,000				Stat. Inventory Reconciliation	Yes
3	03	1/16/2013	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	
5379			Double-Walled	Double-Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Stat. Inventory Reconciliation	Continuous Interstitial Monitor	
6,000				Stat. Inventory Reconciliation	Yes
4	03	1/16/2013	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	
5380			Double-Walled	Double-Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Stat. Inventory Reconciliation	Continuous Interstitial Monitor	
12,000				Stat. Inventory Reconciliation	Yes

Facility Summary in CARBON County in the City of RED LODGE

Location: TOWN PUMP OF RED LODGE
615 NORTH BROADWAY
RED LODGE, MT 59068 CARBON

Sys Fac ID: 60-15212

Last Inspected On: 4/23/2013

Operating Permit Renewal Date: 7/29/2016

Contact: Trent Biggers, (406) 497-6700

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	03	1/16/2013	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	
5381			Double-Walled	Double-Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Stat. Inventory Reconciliation	Continuous Interstitial Monitor	
8,000				Stat. Inventory Reconciliation	Yes

Facility Summary in CARBON County in the City of ROBERTS

Location: Y STOP C STORE INC
4 COONEY RD
ROBERTS, MT 59070 CARBON

Sys Fac ID: 05-06599

Last Inspected On: 2/12/2015

Operating Permit Renewal Date: 2/20/2018

Contact: Roxie Melton, (406) 445-2203

Owners/Operators: Melton Enterprises Inc, Owner (406)-445-2203 DBA Y STOP
4 COONEY RD
ROBERTS MT 59070-9624

Rodney Melton, UST Class A Operator

Rodney Melton, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	23	6/20/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3329			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		2/12/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
5,000			TLS-300 , Veeder Root		
6	23	6/20/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3330			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		2/12/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
3,000			TLS-300 , Veeder Root		
7	23	6/20/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3331			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		2/12/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
3,000			TLS-300 , Veeder Root		
8	23	6/20/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3332			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		2/12/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
5,000			TLS-300 , Veeder Root		

Facility Summary in CARBON County in the City of SILESIA

Location: ROCKVALE TRAVEL PLAZA UST
US HIGHWAY 212 & US HIGHWAY 310
SILESIA, MT 59041 CARBON

Sys Fac ID: 05-07633

Last Inspected On: 12/10/2014

Operating Permit Renewal Date: 2/27/2018

Contact: (406) 962-3886

Owners/Operators: Thomas H McNew, Owner (406)-962-3886 PO BOX 80002
BILLINGS MT 59108-0002
Thomas H McNew, UST Class A Operator
Thomas H McNew, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
6	16	7/1/1999	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
4112		12/10/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Gasoline		12/10/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
7	16	7/1/1999	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
4113		12/10/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Gasoline		12/10/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
10,000			Gilbarco EMC Basic , Gilbarco		
8	16	7/1/1999	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
4114		12/10/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Diesel		12/10/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
10,000			Gilbarco EMC Basic , Gilbarco		